

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08243
Name of Facility: Paul W. Bell Middle School
Address: 11850 NW 2 Street
City, Zip: Miami 33182

Type: Public School
Owner: M-DCSB Food and Nutrition
Person In Charge: Ingrid Soto Phone: 305-220-2075

Correct By: Next Inspection
Re-Inspection Date: None

Inspection Information

Purpose: Routine
Inspection Date: 5/16/2016

Begin Time: 09:15 AM
End Time: 11:00 AM

Additional Information

| | |
|---------|-----|
| CENSUS | 502 |
| FEMALES | 227 |
| MALES | 275 |

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

Violation Markings

| | | |
|------------------------------|-----------------------------------|-------------------------------|
| SCHOOL SANITATION | 11. Cleanliness & Repair | 22. Solid Waste |
| 1. School Site | 12. Toilet Facilities | VECTOR/VERMIN CONTROL |
| 2. Playground Equipment | 13. Separation of Sexes | 23. Infestation/Control |
| 3. Athletic Equipment | 14. Fixture Ratio | 24. Brush/Trash |
| BUILDINGS | 15. Handwash Facilities | 25. Water Collection/Drainage |
| 4. Construction | 16. Showers/Fixtures | SAFETY |
| 5. Maintenance & Repair | 17. Shower Water Temp. | 26. First Aid Kit |
| X 6. Lighting/Foot-Candles | WATER SUPPLY | FOOD |
| 7. Heating, Ventilation, A/C | 18. Installed/Operated/Maintained | 27. Food Insp. Rpt. |
| 8. Natural Ventilation | X 19. Drinking Fountains | OTHER |
| 9. Mechanical Ventilation | 20. Approved Source | 28. |
| SANITARY FACILITIES | LIQUID/SOLID WASTE | 29. |
| 10. Provided/Accessible | 21. Sewage Disposal | |

General Comments

No General Comments Available

Email Address(es): imsoto@dadeschools.net

Inspector Signature:

Client Signature:

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

Violation #6. Lighting/Foot-Candles
Replace lights off missing in the Art class.
CODE REFERENCE: Lighting/Foot-Candles 64E-13.004(4)(a-d). Illumination in all instructional spaces shall be designed to provide a minimum of forty (40) foot-candles glare free at normal task level. Fixtures shall be so located that there will be uniform (within ten (10) foot-candles) illumination suitable for the activities conducted therein. All required illumination shall be designed so that the failure of any single unit, such as the burning out of an electric bulb will not leave any occupied area or means of egress in darkness. Illumination of chalkboards and other visual aids shall be designed to eliminate glare and shadows.

Violation #19. Drinking Fountains
Repair handle not working in the following water fountains :
Next room 96-1,next 218-3,next room 125,next lockers room
Replace rubbers cap have been deteriorated and stain throughout the entire school
CODE REFERENCE: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.

Inspection Conducted By: Zenaida Triana (27455)
Work: (305) 623-3500 ex.
Date: 5/16/2016

Inspector Signature:

Handwritten signature of Zenaida Triana.

Client Signature:

Handwritten signature of Paul W. Bell.